Tinstallations

Providing more 4 wireless

Unit 29 Highlode Industrial Estate,
Stocking Fen Road, Ramsey, PE26 2RB
sales@tcinstallations.co.uk, UK

**Head Office**
+44 (0)1487 710555

## ATEX/IECEx Gland

**Part Number: TCGLND101**

## Description

Compound filled cable gland is for in/out door use in the appropriate hazardous areas with un-armoured cable of any construction, with or without braids or screens, where the braids or screens pass through the compound. It gives environmental protection to IP68 and Deluge.

## Certification:

| | |
|---|---|
| ATEX | SIRA 03ATEX1479X |
| | SIRA 09ATEX4124X |
| IEC | IECEx SIR07.0098X |

**ATEX (EU directive Markings:**

Ex 1 M2 11 2 GD Ex 11 3 GD